

## CERTIFICATE OF APPROVAL

Authorised marking: TUV-026093-EA

CONTINUATION SHEET 21

(Modification 14)

Classified as:

Installed within power conditioning equipment (PCE),  
Enclosed outdoor,  
suitable for installation exposed to sunlight as  
per AS/NZS 5033.

Switch arrangement: GHX6-55P, 6 layers

Installed within Hybrid inverter

Ithe Solar at 40°C: 32A, Ithe Solar at 60°C: 32A

Brand: GOODWE

Models: GW5K-EHB-AU-G11, GW8.6K-EHB-AU-G11

GW9.99K-EHB-AU-G11

®

Size: 415mm×791mm×180mm (W x H x D)

Enclosure material: Aluminum

Issue Date: 06/09/2024

Expiry Date: 27/05/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*



John Wang



[www.jas-anz.org/register](http://www.jas-anz.org/register)