

Certificate Number: AZ 69026318

Page: 0001



CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026318-E

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.

CERTIFICATE HOLDER:

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

DESCRIPTION OF EQUIPMENT

Declared class:

Non-declared

Product:

AC coupled Inverter

Trade Name / Manufacturer:

GOODWE

Model Number:

GW3600-SBP-20 , GW5000-SBP-20 , GW6000-SBP-20

Ratings:

Rating details refer to CONTINUATION SHEET 1-2

Standard:

AS/NZS 4777.2:2020+A1
IEC 62109-1:2010
IEC 62109-2:2011
IEC 62477-1:2012+A1

Issue Date:

19/08/2022

Expiry Date:

19/08/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read "Grant Li", positioned above a horizontal line.

Grant Li



www.jas-anz.org/register

Certificate Number: AZ 69026318

Page: 0002



CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026318-E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings:

Protection: Class I, IP65, PD 2 Internal; PD 3 External

Operating Temp.: -25°C to 60°C (>45°C derating)

Overvoltage Category (OVC): Battery input: I; AC output: III

Battery input:

Battery type: Li-ion

Vmax: 60Vdc

Voltage range: 40 – 60Vdc

Max charge/discharge current: 75/75A, 120/120A, 120/120A

AC output (on grid):

Rated Output voltage: L/N/PE, 230V

Rated frequency: 50Hz,

Max/Rated Output Apparent power: 3.68, 5, 6kVA

Max / Rated Output Power: 3.68, 5, 6kW

Max/Rated Output current: 16.7, 22.7, 27.3A

Power factor: 1 (default), 0.80 leading, 0.80 lagging

Issue Date: 19/08/2022

Expiry Date: 19/08/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read "Grant Li", positioned above a horizontal line.

Grant Li



www.jas-anz.org/register

Certificate Number: AZ 69026318

Page: 0003



CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026318-E

CONTINUATION SHEET 2

DESCRIPTION OF EQUIPMENT

Ratings:

AC output (back-up):

Rated Output voltage: L/N/PE, 230V

Rated frequency: 50Hz,

Max/Rated Output Apparent power: 3.68, 5, 6kVA

Max Output current: 16.7, 22.7, 27.3A

Issue Date: 19/08/2022

Expiry Date: 19/08/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

TÜVRheinland

A handwritten signature in blue ink, appearing to read "Grant Li", positioned above a horizontal line.

Grant Li



www.jas-anz.org/register